

# Brief analysis of variable renewable energy contribution during loadshedding (Q1-2019)

CSIR Energy Centre

*CSIR Energy Centre*  
*Pretoria. 9 April 2019*  
*v1.0*

JARRAD **WRIGHT**  
[jwright@csir.co.za](mailto:jwright@csir.co.za)

JOANNE **CALITZ**  
[jrcalitz@csir.co.za](mailto:jrcalitz@csir.co.za)

**CSIR**  
*our future through science*

# Key takeaways

## A constrained power system meant South Africa had to loadshed again in Q1-2019

- The RSA power system again became constrained in Q1-2019 with Eskom needing to loadshed (to Stage 4 at times)
- Causes of loadshedding have been cited as high unplanned plant failures on the thermal coal fleet, depleted diesel (OCGTs) and water (pumped storage) combined with the loss of Cahora Bassa import from Mozambique
- This has been the most intensive loadshedding experienced in RSA with 595 GWh of load shed just in March 2019 of the total 769 GWh in Q1-2019 (there was 1325 GWh of loadshedding throughout 2015)


## The utility-scale VRE fleet notably contributed to limit the extent of loadshedding in Q1-2019

- The utility-scale VRE fleet<sup>1</sup> contributed 2 975 GWh (5.3%) to the RSA power system in Q1-2019 with monthly contributions ranging from 4.9-6.0%, weekly contributions from 4.1-7.0% and daily contributions from 2.9-7.7%
- During loadshedding periods, the utility-scale VRE fleet contributed 357 GWh of the total 2975 GWh from VRE during Q1-2019 i.e. loadshedding could have increased from 769 GWh to 1126 GWh (a 46% increase)
- Instantaneous contributions from the VRE fleet during loadshedding periods was up to 2.3 GW i.e. without the VRE fleet, loadshedding stage 5 & 6 could have been invoked

<sup>1</sup> 1.5 GW solar PV, 2.0 GW wind and 0.5 GW CSP; RSA = Republic of South Africa; VRE = variable renewable energy

# First 3 months of 2019 – most intensive loadshedding in March with 595 GWh of 769 GWh in 2019... 1325 GWh throughout 2015


GWh of load shedding



Notes: Load shedding assumed to have taken place for the full hours in which it was implemented. Practically, load shedding (and the Stage) may occasionally change/end during a particular hour; Total GWh calculated assuming Stage 1 = 1 000 MW, Stage 2 = 2 000 MW, Stage 3 = 3 000 MW, Stage 4 = 4 000 MW


Sources: Eskom Twitter account; Eskom se Push (mobile app); CSIR analysis

# Loadshedding in 2015 predominantly during high demand periods (day and evening peaks)... most recently in 2019 this has been day/night



Notes: Load shedding assumed to have taken place for the full hours in which it was implemented. Practically, load shedding (and the Stage) may occasionally change/end during a particular hour; Total GWh calculated assuming Stage 1 = 1 000 MW, Stage 2 = 2 000 MW, Stage 3 = 3 000 MW, Stage 4 = 4 000 MW  
Sources: Eskom Twitter account; Eskom se Push (mobile app); CSIR analysis

# Procured and operational capacity under RSA's RE IPP Procurement Programme (REIPPPP) by Q1-2019




Notes: RSA = Republic of South Africa. Wind excludes Eskom's Sere wind farm (100 MW). BW = Bid Window. PPA = Power Purchase Agreement. BW 4 includes BW 4 additional.

Sources: Eskom; DoE IPP Office; <http://www.energy.gov.za/files/renewable-energy-status-report/Market-Overview-and-Current-Levels-of-Renewable-Energy-Deployment-NERSA.pdf>




# From 1 November 2013 to 31 March 2019, 2 078 MW of wind, 1 479 MW of large-scale solar PV and 500 MW of CSP became operational in RSA



# In Q1-2019 - 3.0 TWh of wind, solar PV and CSP energy was produced in RSA with estimates of over 12 TWh for 2019 expected

Annual energy produced  
[TWh]




Notes: Wind includes Eskom's Sere wind farm (100 MW). CSP energy measured from date when more than two CSP plant were commissioned.

Wind and solar PV energy excludes curtailment and is thus lower than actual wind and solar PV generation

Sources: Eskom; DoE IPP Office

# Monthly electricity production of SA's wind, solar PV and CSP fleet ranging from 4.9-6.0% (similar to previous year)

Monthly electricity production in GWh



Note: Wind generation includes Eskom's 100 MW Sere wind farm. CSP energy only measured from date when more than two CSP plant were commissioned.


Wind and solar PV energy excludes curtailment and is thus lower than actual wind and solar PV generation.

Sources: Eskom; CSIR Energy Centre analysis



# Monthly electricity production from wind, solar PV, CSP, residual load and loadshedding impact in Q1-2019

Monthly electricity production in TWh




Notes: Pumping load excluded. Wind generation includes Eskom's 100 MW Sere wind farm.

Sources: Eskom; CSIR Energy Centre analysis


# Weekly contribution from utility-scale RE in first 3 months of 2019 ranges from 4.1-6.9% of total system demand

Electricity production  
in GWh/week



# Weekly electricity production wind, solar PV, CSP, residual load and loadshedding in Q1-2019

Electricity production  
in GWh/week



Capacity  
operational

1479 MW

2078 MW

500 MW

Supply  
Sources

Loadshedding

CSP


Solar PV

Wind

Residual  
Load


# For Jan-Mar 2019, electricity production from wind, solar PV and CSP was above 25 GWh/d 90% of the time with maximum of 48 GWh/d

Electricity production  
in GWh/day




Note: Design as per Fraunhofer ISE. Wind includes Eskom's Sere wind plant.  
Sources: Eskom; CSIR Energy Centre analysis

# Daily electricity production of between 543-666 GWh in Jan 2019 with VRE contributing 5-8%




Note: Design as per Fraunhofer ISE. Daily production excludes pumping load. Wind includes Sere.  
Sources: Eskom; CSIR Energy Centre analysis

# Daily electricity production of between 593-672 GWh/d in Feb 2019, VRE supplied 3-6% of system demand and up to 7% of load was shed







# Daily electricity production of 538-658 GWh/d in Mar 2019, VRE contributed 3-7% everyday and up to 14% of load was shed



# Hourly VRE production in Jan 2019 shows periodic solar PV and CSP; wind varies but contributes notably during evening peaks




# Hourly VRE electricity production in Feb 2019 shows how loadshedding could have increased to Stage 5-6 without VRE




Note: Design as per Fraunhofer ISE. Pumping load excluded.  
Sources: Eskom; CSIR Energy Centre analysis

# Hourly VRE electricity production in Mar 2019 shows again how loadshedding could have increased to Stage 5-6 without VRE




Note: Design as per Fraunhofer ISE. Pumping load excluded.  
Sources: Eskom; CSIR Energy Centre analysis

# Hourly electricity production in Jan 2019 highlighting role of VRE fleet




Note: Design as per Fraunhofer ISE. Pumping load excluded.  
Sources: Eskom; CSIR Energy Centre analysis

# Hourly electricity production in Feb 2019 with 5 days of loadshedding






# Hourly electricity production in Mar 2019 with 10 days of loadshedding




# Significant contribution from VRE during loadshedding in Feb 2019 – 103 GWh and a maximum inst. contribution of 2.0 GW



# Similarly, VRE provided valuable capacity during loadshedding in March 2019 – 254 GWh and a maximum inst. contribution of 2.3 GW

Power in GW


Week of 18-24 March 2019



# VRE reduced peak by 1.1 GW & high demand hours notably; loadshedding could have increased by as much as 46% without VRE

Power in GW

LDC (1 Jan – 31 Mar 2019)



LDC = Load Duration Curve; <sup>1</sup> When demand is >90% of peak demand;  
VRE = variable renewable energy (solar PV, wind and CSP)

Sources: Eskom; CSIR Energy Centre analysis

Thank you